



## SPECIFICATION SHEET: Fire Series FC3 (EW-BI) Active Fire Curtain Barrier

### Testing or Classification:

<b>BS EN 1634-1:2008</b>	Fire resistance & smoke control tests for door, shutter and openable window assemblies and elements of building hardware. Fire resistance tests for doors, shutters and openable windows.
<b>BS EN 1363-1:1999</b>	Fire resistance tests. Part 1: General requirements
<b>BS EN 1363-2:1999</b>	Fire resistance tests. Part 2: Alternative & additional procedures.
<b>BS EN 13501-2:2007+ A1:2009</b>	Fire classification of construction products and building elements. Classification using test data from fire resistance tests, excluding ventilation services ratings
<b>BS8524-1:2013</b>	Active fire curtain barrier assemblies. Annex D. Reliability, Response Time & Durability Tests
<b>BS EN 14600:2005</b>	Doorsets & openable windows with fire resisting and / or smoke control characteristics. Requirements & classification.
<b>BS EN ISO 9001:2008</b>	Quality management system
<b>BS EN 10219-1:1997</b>	Cold formed welded structural sections of non-alloy and fine grain steels.
<b>BS EN 10025-2:2004</b>	Hot rolled products of structural steels.
<b>BS EN 10305-3:2002</b>	Specification for seamless & welded tubes for automobile, mechanical & general purposes. Specific requirements for electric resistance welded (including induction welded) steel tubes.
<b>Fabric Testing</b>	DIN EN 12654; 12127. DIN ISO 9354; 4603/E & 4606

### Performance & Classification

240 minutes integrity up to 1000 °C (1832°F)  
Approved for spans of 4m in width, heights up to 4m.  
90 minutes <15kW/m<sup>2</sup>  
E240 EW90 Class "0" B-s1, d0

### FC2 Compliance Parameters:

- tested for fire resistance to BS EN 1634-1
- provides gravity fail safe operation
- motors within the assemblies tested to operate at temperatures up to 300 °C
- fabric compliance included in BS EN 1634-1

### Product Performance:

Complete product tested to BS EN1634-1:2008 and achieved up to 1000° C for 240 minutes and is ASB 1 and 3 classified.  
Designed to operate for 5000 cycles at normal ambient temperatures.

### General Description:

The active fire curtain barrier consists of a 05315-2-BI intumescent silicone / graphite coated , stainless steel wire reinforced glass fabric. The fabric is tested to withstand temperatures of up to 1000°C for a period of 240 minutes minimum & an irradiance protection of up to 90 minutes, this is wound onto a steel tube, each of which will incorporate a 24 volt d.c. motor, a sealed heavy duty ball bearing assembly, and an electronic control circuit. The active roller assembly, incorporating the fabric, is housed in galvanised mild-steel head box which is normally bolted to the fabric of the building.

Standard head box sizes are 210mm x 210mm. Larger head boxes may be required where the curtain drop is in excess of three metres. Also, the lower edge of the curtains incorporates a twin inverted mild steel angle which acts as a weight bar to enable the curtain to unwind upon receipt of a signal from the fire alarm panel or total mains and battery failure. Various oversize assessments have been conducted.

Metal side guides with a fabric retaining system shall be installed to provide a seal between the curtain fabric and the building construction.

### Control system:

Operation of the curtains is via the Group Control Panel which can either be mounted adjacent to the fire curtain head box within the ceiling void, allowing access for maintenance, or mounted in a remote position from the curtain.

The panel requires a local 230v ac supply rated at 3 amps via an un-switched fused spur on a maintained supply installed by others. For operational purposes the G.C.P. must be connected to a normally-closed volt-free contact within the fire alarm control panel configured to open on fire and fail safe.



MAKING BUILDINGS SAFER

# Smoke & Fire Curtains

+44 (0) 114 251 4703  
ble-smokeandfirecurtains.com

Each control panel is capable of operating up to six rollers and includes battery back-up which will maintain the curtains in their retracted position for a period of three hours during a mains failure. It is also possible to manually operate the curtains for twenty cycles during this period.

Should the battery voltage fall below a predetermined limit, a low voltage cut off circuit will activate the curtain, which will descend in a controlled manner under the power of gravity.

The roller motors, which are 24 volt d.c., must be wired from the G.C.P. in a ring main using suitably sized cable to ensure a voltage of 24v d.c -10%.

The curtains descend upon receipt of a signal from the fire-alarm panel and retract when the signal is removed. During ascent the motors are controlled via a synchronised speed circuit to ensure all curtains are raised at similar rates. In the event of mains and battery backup failure, the curtains descend under the force of gravity.

Limit switches are not used to control the upper and lower positions of the curtain.

There is a manual key operation from GCP to facilitate override and testing.

## **Optional Extras:**

### **Split drop delay:**

An optional braking system is available to allow a two stage descent during gravity deployment. This provides partial descent to a predetermined level to permit preliminary escape and initial smoke containment. After delay the barrier descends to its full operational position.

### **Voice warning:**

Audio or spoken multi message facility.

### **Obstruction warning:**

A beam detector which will sound in the event of any obstruction being placed in the curtain drop line.

### **Visual alert system:**

Standard localised light or strobe light.

### **Emergency retract:**

Manual operation to momentarily retract for occupant escape and emergency service access

### **Walk through escape:**

A push-through overlap to provide means of passage through the barrier once deployed.

### **Others:**

Other variants are available such as manual reset, curtain decals and signage and delayed descent.

## **Manufacturer**

BLE Smoke & Fire Curtains Ltd

Unit 3 Holbrook Commerce Park, Holbrook Rise, Sheffield. S20 3FJ. United Kingdom

Tel: +44 (0) 114 251 4703

Fax: +44 (0) 114 251 3908

Email: [enquiries@blecurtains.com](mailto:enquiries@blecurtains.com)

Web: [www.ble-smokeandfirecurtains.com](http://www.ble-smokeandfirecurtains.com)

## **Warranty**

The manufacturer will provide a written warranty for a period of one year. Exclusions may apply if any element is sublet to any unauthorised party.